

This report is a summary of the quality of the water we provide our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. We hope this information helps your become more knowledgeable about what's in your drinking water.

Public Participation Opportunities

Date: July 14, 2025

Time: 6:00 p.m.

Phone: (940) 479-7010

Location: Town of Ponder

102 W. Bailey Street

Ponder, TX 76259

To learn about future public meetings (concerning your drinking water), or to request to schedule one, please call us.

Questions

If you have questions about this report or your water service, please contact Gary Morris at (940) 479-7010.

En Español

Este informe incluye información importante sobre el agua potable. Si tiene preguntas o comentarios sobre éste informe en español, favor de llamar al tel. (940) 479-7010 - para hablar con una persona bilingüe en español.

www.pondertx.com



Town of Ponder

PWS ID# TX 0610039

102 W. Bailey Street

Ponder, TX 76259

PRESORTED STANDARD
U.S. POSTAGE
PAID
WICHITA FALLS, TX
PERMIT 600



PWS ID# TX0610039

2024 Annual Drinking Water Quality Report

2024 Test Results

We routinely monitor for constituents in your drinking water according to Federal and State laws. The test results table shows the results of our monitoring for the period of January 1st to December 31st, 2023.

Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample	1		0	No	Naturally present in the environment.

Copper

Contaminant (Units)	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Violation	Likely Source of Contamination
Copper (ppm)	8/30/2023	1.3	1.3	0.086	0	No	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.

Disinfection By Products

Contaminant (Units)	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5) (ppb)*	2024	2	2.3-2.3	No goal for the total	60	No	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM) (ppb)**	2024	3	2.89-2.89	No goal for the total	80	No	By-product of drinking water disinfection.

* The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year.

**The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year.

Inorganic Contaminates

Contaminant (Units)	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Violation	Likely Source of Contamination
Barium (ppm)	2024	0.054	0.041-0.054	2	2	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium (ppb)	2024	3.5	3.5-3.5	100	100	No	Discharge from steel and pulp mills; Erosion of natural deposits.
Cyanide (ppb)	9/14/2023	37.7	0-37.7	200	200	No	Discharge from plastic and fertilizer factories. Discharge from steel/metal factories.
Fluoride (ppm)	2024	0.204	0.0741-0.204	4	4.0	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate (measured at Nitrogen) (ppm)	2024	0.32	0.0108-0.32	10	10	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Radioactive Contaminates

Contaminant (Units)	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Violation	Likely Source of Contamination
Combined Radium 226/228 (pCi/L)	6/28/2021	1.5	1.5-1.5	0	5	No	Erosion of natural deposits.

Synthetic Organic Contaminants Including Pesticides and Herbicides

Contaminant (Units)	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Violation	Likely Source of Contamination
Di (2-ethylhexyl) adipate (ppb)	2024	2.4	0-2.4	0	6	No	Discharge from rubber and chemical factories.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

Definitions

The charts on the following pages may contain terms and abbreviations with which you are not familiar. To help you better understand these terms we've provided the following definitions:

Action Level (AL) – the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Avg. – Regulatory compliance with some MCLs is based on running annual average of monthly samples.

Level 1 Assessment – A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment – A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MFL – million fibers per liter (a measure of asbestos).

mrem – millirems per year (a measure of radiation absorbed by the body).

NA – not applicable.

NTU – nephelometric turbidity units (a measure of turbidity).

Picocuries per liter (pCi/L) – a measure of radioactivity.

Parts per billion (ppb) – micrograms per liter or parts per billion

Parts per million (ppm) – milligrams per liter or parts per million

Parts per quadrillion (ppq) – picograms per liter

Parts per trillion (ppt) – nanograms per liter

Treatment Techniques or TT – A required process intended to reduce the level of a contaminant in drinking water.

Disinfectant Residual

Contaminant (Units)	Collection Date	Average Level	Range of Levels Detected	MRDL	MRDG	Violation	Source of Drinking Water
Free (ppm)	2024	1.65	1.57-2.20	4	4	No	Water additive used to control microbes.

Lead/Copper inventory begun - Customers have been notified

VIOLATIONS

Public Notification Rule

The Public Notification Rule helps to ensure that consumers will always know if there is a problem with their drinking water. These notices immediately alert consumers if there is a serious problem with their drinking water (e.g., a boil water emergency)

Violation Type	Violation Begin	Violation End	Violation Explanation
NONE			

Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Where Do We Get Our Drinking Water?

The Town of Ponder has six water wells, and provides ground water from the Trinity Aquifer, located in Denton County. The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants may be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, contact Gary Morris (940) 479-7010 or email abril.caranza@tceq.texas.gov.

All Drinking Water May Contain Contaminants

When drinking water meets federal standards there may not be any health benefits to purchasing bottled water or point of use devices. Drinking water, including bottled water, may reasonably be expected to contain at least small amount of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Secondary Constituents

Many constituents (Such as calcium, sodium, or iron) which are often found in drinking water, can cause taste, color, and odor problems. The taste and color constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concern. Therefore, secondaries are not required to be reported in this document but they may greatly affect the appearance and taste of your water.

Additional Health Information for Lead

If present, elevated levels of lead can cause serious health problems; especially for pregnant women and young children. Lead in drinking water is primarily from material and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking.

If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <https://www.epa.gov/safewater/lead>.

